

The Eagle Group

Administrations Office

2520 West Washington, Suite 200

Yakima, Washington 98903

Main Office: (800) 452-1510**Fax: (509) 452-5629****Fax Cover Sheet**

To: EPA, Underground Storage Tank Division
Attn: Goeff Keeler
Fax: (206) 553-0165

From: Dustin Ramsey
The Eagle Group
Administrative Office
2520 West Washington, Suite 200
Yakima, WA 98903

The following 1 page(s) are being faxed to you immediately following this cover sheet (for a total of 2 pages).

Notes concerning fax:

Dear Geoff,

The following page consists of the letter faxed to myself from Kennedy Equipment Co., Inc. It reviews the test of the tank monitoring system conducted on the Eagle Stop & Save convenience store in Wapato, Washington on January 25, 1996. The tests indicate that the tank monitor is calibrated and operating within tolerance, and that all functions were normal. The tanks are numbered 1-3, with the #1 tank closest to the building, and the #3 tank furthest away. The products in the tanks are as follows: Tank 1, Unleaded-Plus; Tank 2, Unleaded; Tank 3, Super Unleaded. If you have any questions or concerns, please call me.

Thank you,


Dustin Ramsey
Vice-President
The Eagle Group

KENNEDY EQUIPMENT CO. INC. THE GAS PUMP PEOPLE

510 3rd ST.
CLARKSTON WA. 99403
(509) 758-2493
(FAX) 758-6960

603 AINSWORTH
PASCO WA 99301
(509) 545-2163
(FAX) 545-5351

814 S COLUMBIA
WENATCHEE WA. 98801
(509) 886-7867
(FAX) 662-0764

ROUTE 3 BOX 158
MILTON-FREEMAN OR. 97862
(503) 938-4466
(FAX) 938-0266

ATT: DUSTIN RAMSEY

IN REFERENCE TO THE TIDEL TANK MONITOR AT EAGLE STOP & SAVE
WAPATO WASHINGTON. ON 01-25-96 THE TANK MONITOR WAS CHECKED FOR
ALARMS AND ACCURACY. NO ALARMS WERE NOTED AT THAT TIME. ALSO AT
THAT TIME THE TANK LEVELS WERE CHECKED RESULTS ARE AS FOLLOWS,
TANK # 1 SUPER UNLEAD STICK READING WERE 29.75" MONITOR 29.81"
TANK # 2 UNLEAD STICK READINGS 81.5" MONITOR 83.5" DIFF 2"
TANK # 3 REGULAR STICK READINGS 47.25" MONITOR 47.33"
AT THIS TIME THE TANK MONITOR WAS OPERATING WITHIN TOLERANCE.
ALL FUNCTIONS AT THIS TIME WERE NORMAL.

Sales - Service & Installation
Hoists - Pumps - Tanks - Nozzles
Dispensers, Etc.

KENNEDY EQUIPMENT CO., INC.
The Gas Pump People

ED MITCHELL

Installation - Retrofit
Decommissioning - Site Assessment

Pasco, Washington 99301
(509) 545-2163
FAX (509) 545-5351

